

**!! CAUTION !!**

This instrument emits a high frequency, high voltage spark. Keep the electrode tip away from the body. Care should be taken to avoid letting the spark be attracted to metal objects worn on the body such as rings and jewelry. A spark to the body will not cause harm, but might cause a slight discomfort, like the sensation felt when a spark jumps from the finger tip to a metal object after having walked across a carpet on a dry day. The output of the instrument is at a very low current. Also, the skin of the body has a very high resistance to the high frequency current, causing any current to flow harmlessly over the skin.

Do not operate in or around flammable liquids or gases as the spark may ignite them.

Ozone gas is generated around the tip of the electrode when oxygen in the air is ionized. The gas has a pungent odor, but is harmlessly dissipated in a normally ventilated area. Do not use in a confined area where high concentrations of ozone gas can develop.

This instrument generates an output at the radio-frequency level. Users who wear a pacemaker, or use other medical electronic devices which might be affected by radio-frequency waves, are advised to consult a physician before using this instrument.

## **SECTION 1 - GENERAL INFORMATION**

### **1.1 Description**

- 1.1.1 The Models BD-20C and BD-20CV High Frequency Generators produce a high voltage, high frequency spark at the tip of an electrode. The electric field created around the electrode is used for surface treating of polymers.
- 1.1.2 The Generator and associated electronic and mechanical assemblies are housed in a durable Bakelite case which can be held comfortably in the hand. It has a 6 ft (1.8 m) power cord to permit ample movement over the work surface. Power is supplied by a transformer which is housed in a separate unit for better heat dissipation. This case is finished in a durable, silicone-based paint which is scratch resistant. Metal tabs are incorporated into the case for permanent mounting.
- 1.1.3 The Power Supply is furnished with a polarized and grounded power line cord 6 ft. in length. Operation is from 115 volts, 50/60 Hz for the Model BD-20C, and 230 V, 50/60 Hz for the Model BD-20CV. Each model is equipped with a line cord plug which meets US electrical code configurations for that voltage.
- 1.1.4 Both models are supplied with two electrodes.

## 1.2 Packing List

- 1.2.1 Carefully remove the instrument and accessories from the packing materials. Check all parts against the Packing List. Report any shortages immediately.

Quantity	Part/Model No.	Description
1	080-1201-1	Generator
1	080-1200-1	Power Supply, 115 V (BD-20C)
1	080-1202-1	Power Supply, 230 V (BD-20CV)
1	12801	Electrode, Round, 1/2 in.
1	13811	Electrode, Field Effect, 3 in.
1	085-0057-3	Instruction Manual

## 1.3 Specifications

<b>Output Voltage</b>	10,000 to 50,000 volts
<b>Frequency</b>	4 to 5 MHz
<b>Operating Duration</b>	Continuous
<b>Input Voltage</b>	BD-20C: 115 V, 50/60 Hz BD-20CV: 230 V, 50/60 Hz
<b>Generator (L x D)</b>	11 x 2-1/2 in. (28 x 6.4 cm)
<b>Power Supply (H x W x D)</b>	4-1/8 x 7-3/4 x 3-1/8 in. (10.5x19.7x8cm)
<b>Shipping Weight</b>	BD-20C: 6 lbs (2.7 kg) BD-20CV: 7 lbs (3.2 kg)

## 1.4 Warranty Repair / Replacement Information

- 1.4.1 Forward the instrument, freight prepaid to the factory or distributor from which it was purchased, along with a copy of the invoice for warranty verification. The instrument is date coded as to the date of manufacture.
- 1.4.2 UV Process Supply, Inc. reserves the right to repair or replace any instrument sent in for warranty repair.
- 1.4.3 Instruments found to be out of warranty will be repaired for a minimal labor and parts charge, unless directed to do otherwise. If it is determined that repair costs will exceed the cost of a new instrument, the customer will be so advised.
- 1.4.4 Parts for discontinued models will be made available, wherever possible, for a minimum period of five years after the model has been discontinued.

## SECTION 2 - INSTALLATION

### 2.1 Installation

- 2.1.1 The instrument should be located away from sources of heat or air conditioners. Avoid areas of high humidity or highly corrosive atmospheres; if operation is required under any of these conditions, use intermittently and remove to another location for storage.
- 2.1.2 Do not use near flammable liquids or explosive gases.

## **2.2 Assembly**

- 2.2.1 Connect the plug from the Generator into its matching receptacle on the Power Supply. The plug is polarized to fit into the receptacle only one way. Arrows indicate its proper position in the socket. Do not attempt to force the plug into the receptacle. Rotate until it fits easily; once properly seated, push firmly into place.
- 2.2.2 Connect the power line cord to its matching three wire power line receptacle. This provides power properly polarized and grounded. Operation in any other way will result in a potential shock hazard and may affect the performance of the instrument.
- 2.2.3 If it is necessary to replace the power line plug with a different type for use outside of the United States, use one with a ground connection and install following this wiring convention: black wire to the high side of the power line; white to the neutral side of the power line; green wire to earth ground.

## **2.3 Accessory Information**

- 2.3.1 Push either of the electrodes furnished into the matching socket in the Generator. To remove the electrode, firmly grasp the metal base of the electrode which protrudes about 1/4 in. (6 mm) from the case and gently rock back and forth while pulling it out. Do not install or remove the electrode while in operation.

## **SECTION 3 - OPERATION**

### **3.1 Operation Controls**

- 3.1.1 Power ON/OFF Switch. Located on the side of the Power Supply case. In the ON position, circuitry is energized.
- 3.1.2 High Voltage Adjust Knob. Located on the end of the Generator case opposite the electrode, adjusts the spark length by changing the spacing between the tungsten contacts inside. A clockwise rotation increases the spark length.

### **3.2 Calibration**

- 3.2.1 The instrument requires no user calibration internally. However, use of a Peak Voltage Calibrator is recommended if setting the output voltage accurately and with repeatability is required.

### **3.3 Operation**

- 3.3.1 Bring the electrode tip near a large metal object or a ground connection. Turn the Power Switch to the ON position. If no spark is seen to jump from the electrode, the spark is being confined between the two internal tungsten contacts in the Generator. (NOTE: An associated electric field can be felt near the location of the tungsten contacts located opposite the electrode side of the Generator.) While the electrode is near the metal object, turn the High Voltage Adjust Knob until the spark is seen to jump from the electrode to the metal surface.
- 3.3.2 Continue to turn the knob until a spark of the desired length emanates from the electrode. A nearly linear relationship exists between spark length and spark voltage. A 1 in. (25 mm) spark represents peak voltages of approximately 50,000 volts; a 1/2 in. (13 mm) spark, 25,000 volts. Adjust the length of the spark most suitable for the application. Usually the proper spark length is determined through experience; however, the shortest possible spark length should be used to achieve the desired

effect. This device is classified as a Tesla Coil, which is an induction coil generating high frequency, high voltage.

### 3.4 Corona Surface Treating

3.4.1 The surface of polymers is modified by corona treatment at a characteristic rate which varies with the material treated. Also, the degree of treatment, or extent of surface modification required, will depend on the particular application.

3.4.2 The guidelines below are given to help determine the optimal conditions for a particular application, as the surface effect produced by corona treatment depends upon the following:

- treatment time
- power
- distance between electrode and surface to be treated
- electrode size and shape
- area being treated
- material being treated

3.4.3 Treatment Time The most important variable in nearly all applications is treatment time. Treatment effect, measured by an increase in surface energy, is approximately an exponential function of time, and most of the treatment effect therefore occurs quickly. The characteristic time, is determined by electrode size, power, etc.

3.4.4 Power Power is adjusted by the control knob of the end of the handle. The product of power and time is effectively constant for any application. In other words, reducing the power in half will double the time required to obtain the same treatment, when all other parameters are held constant.

3.4.5 Distance between electrode and surface The distance between the electrode and the surface to be treated can be varied. Normally the most efficient treatment is obtained at distances between 1/8 and 1/4 in. Significant treatment can still be obtained at distances as great as 2 in., though treatment times become longer.

3.4.5.1 For example, the treatment done in 0.25 seconds at 1/2 in. may take 15 seconds to do the same treatment at a distance of 1 1/2 in. A qualitative feel for the distance over which the corona is effective can be obtained by visual inspection of the purple corona. This is best done in a darkened room.

3.4.5.2 A metallic conductor within about 2 in. of the electrode (a floating ground plate) will pull the corona in the direction of the plate. This may permit more efficient treatment at larger distances from the electrode, but the treated area is somewhat smaller. The conductor may be quite thin (e.g., copper clad printed circuit board material, standard aluminum foil), but it must be covered with a dielectric to prevent arcing from the electrode.

3.4.6 Electrode Size and Shape Two electrodes are furnished, a circular and a field-effect electrode. Larger size electrodes in these shapes are not practical for use with the Models BD-20C and BD-20CV because of power limitations.

3.4.6.1 The circular electrode is used primarily to treat flat surfaces. The diameter of the maximum width of the surface to be treated is generally about 1 in. greater than the diameter of this electrode.

3.4.6.2 The field-effect electrode is used to treat thick or irregularly-shaped surfaces. This patented electrode can project the corona up to 2 in.

- 3.4.7 Treated Area The treated area is determined by several factors, including the electrode size and shape, power and time. A larger electrode will treat a larger area, but the effect at any one point will take longer to occur.
- 3.4.7.1 The function:  $[(\text{time} \times \text{power}) / \text{area}]$  is an effective constant. So doubling the treated area (by using an electrode which is twice the size) will require twice the time to achieve the same treatment level if the power setting is unchanged.
- 3.4.8 Material Treated The untreated surface energy and the maximum surface energy obtained by corona treatment depend on the material. The amount by which the surface energy is to be increased must be established for each application.

## **SECTION 4 - MAINTENANCE**

### **4.1 General**

- 4.1.1 The instrument contains no user adjustable components inside either the Power Supply or Generator. Any attempt at repair while the instrument is in warranty will void the warranty.
- 4.1.2 Several components will exhibit wear with extended use and will eventually require replacement. The failure modes of several of these components are very similar to what causes the failure of a tungsten-filament incandescent light bulb after extended use.
- a) Due to a combination of corona discharge, high voltage, and high temperature, the insulation in the capacitors and resonator coil may eventually fail. Corona discharge develops around microscopic bubbles within the insulation material. Within time the corona discharge creates larger bubbles. The process accelerates until eventually a voltage breakdown occurs.
  - b) In time the tungsten contacts will require replacement in order to maintain the proper setting of the high voltage output.
  - c) When used continuously or for extended periods of time, the tungsten contacts will begin to evaporate and condense on the plastic molded base of the Part Number 035-0002-1 Generator Mechanical Assembly, causing a short to develop across this component.
- 4.1.3 It is recommended that whenever this instrument requires service, it be returned to the factory or distributor freight prepaid, with a statement concerning the problem. The instrument will be repaired for a nominal labor and parts charge.

### **4.2 Repair**

- 4.2.1 Only personnel familiar with electronic circuitry should attempt repair. If it is necessary to repair while either the Power Supply cover or Generator housing are removed, be cautious as high voltage will be present at various locations in the circuitry. Refer to the Schematic Wiring Diagram at the end of this manual.
- 4.2.2 The Power Supply cover is removed as follows:

- a) Remove the two screws from the side flap of the cover.
- b) Carefully lift the cover from the case and move it to the side. The wiring attached to the jack prevents the complete removal of the case cover.

4.2.3 The Generator housing is disassembled as follows:

- a) Remove the electrode from the socket.
- b) Carefully remove the recessed hex nut holding the electrode socket to the threaded nylon stud attached to the resonator coil. Remove the electrode socket.
- c) Turn the High Voltage Adjust Knob fully counterclockwise. Place a small wrench on the flattened portion of the shaft to hold it from turning while the knob is turned counterclockwise and removed from the shaft.
- d) Note the number of washers around the shaft, and then remove them. Washers are placed on the shaft to prevent the possibility of the two tungsten contacts inside the housing from shorting whenever the High Voltage Adjust Knob has been turned fully clockwise. The number of washers will vary from unit to unit, from none at all, to as many as three.
- e) Remove the wax covering the two screws on the Generator housing near the High Voltage Adjust Knob and remove the screws.
- f) The Generator housing is in two parts. Grasp the grooved portion and turn the other portion counterclockwise to remove.
- g) Carefully remove the electronic and mechanical assemblies from the grooved portion of the housing. The high voltage cord set attached to the electronics will prevent the complete removal of the assemblies from the housing.

4.2.4 The factory maintains stock of replacement parts. Consult the Parts List. A Parts Price List is available upon request.

4.2.5 Refer to Section 4.1.2 for assistance in troubleshooting possible failure modes. If the Generator were accidentally dropped on the High Voltage Adjust Knob, it may be necessary to replace the Part Number 059-0004-1 Bridge Yolk Assembly to repair the unit.

4.2.6 Once repair is completed, carefully reassemble the Power Supply cover and Generator housing.

- a) Reinstall the proper number of washers on the shaft of the Generator. When any of the mechanical components of the Generator are replaced, the number of washers required after repair may be different than before. Use a sufficient number of washers to preclude the possibility of the tungsten contacts from shorting.
- b) Replace the protective wax over the two screws on the Generator housing.